

Rapporto/Report No. K 1203 2019 B71

Decreto 7 Novembre 2017, n. 186
Certificazione ambientale del generatore di
calore

Modelli / Models:
BOILER34FO-AUTO; BOILER34FO-PA

Produttore / Manufacturer:
AMG S.p.A

Marchio commerciale / Trademark:
FOCO

This report may only be published and forwarded to third parties in its complete, unabridged form. The publication or dissemination of extracts, summaries, appraisals or any other adaptation and alterations, in particular for advertising purposes, is only permissible with the prior written permission of TÜV Rheinland.

Publication of page 2 is permitted.

Decreto 7 Novembre 2017, n. 186

Certificazione ambientale del generatore di calore

Produttore / <i>Manufacturer:</i>	AMG S.p.A Via delle Arti e dei Mestieri, 1/3 I-36030 San Vito di Leguzzano (VI)
Marchio commerciale / <i>Trademark:</i>	FOCO
Modelli / <i>Models:</i>	BOILER34FO-AUTO; BOILER34FO-PA
Tipologia prodotto / <i>Product type:</i>	Caldaia a pellets di legna / <i>Wood pellet boiler</i>
Norma di riferimento / <i>Reference standard:</i>	EN 303-5:2012
Ente Notificato CPR/ <i>Notified body acc. CPR</i>	NB 2456
Rapporto di Prova di riferimento / <i>Reference test report:</i>	K12032019E41
Potenza termica nominale / <i>Nominal heat output:</i>	31,2 kW
Combustibile di prova / <i>Test fuel:</i>	Pellet di legna / <i>wood pellet</i>

Prestazioni del generatore di calore <i>Performances of the heating appliance</i>		Classi di prestazione / <i>Performance classes</i>			
		5 stelle	4 stelle	3 stelle	2 stelle
PP⁽¹⁾ mg/Nm ³	11	10	15	20	40
COT⁽¹⁾ mg/Nm ³	3	5	10	15	20
NOx⁽¹⁾ mg/Nm ³	120	120	130	145	200
CO⁽¹⁾ mg/Nm ³	29	25	100	250	300
η⁽¹⁾ %	94,0	92	91	90	90

⁽¹⁾ Determinato applicando il metodo di misura della UNI EN 303-5
Determined applying the measurement method of the UNI EN 303-5

Nota: tutti i valori di concentrazione calcolati al 13% di O₂ in condizioni normali (273 K, 1013 mbar, gas secco)

Note: all the concentration values are calculated at 13% of O₂ in normal conditions (273 K, 1013 mbar, dry gas)

Sulla base delle prestazioni indicate, il generatore di calore risulta in classe
Based on the declared performances, the heating appliance is in class


4 stelle / 4 stars

Cologne, 11.02.2019
 432 / mc

TÜV Rheinland Energy GmbH
 Test Centre for Energy Appliances
 NB 2456 (CPR)
 DIN EN ISO/IEC 17025:2005
 accreditation: D-PL-11120-04-00

Assessor:

Report released after review:


 Dipl.-Ing. M. Ciccarelli


 Dipl.-Ing. A. Pomp